



Certificate of Compliance

Certificate: 2434983

Master Contract: 163545

Project: 70149904

Date Issued: 2017-09-12

Issued to: Eaton Corporation
1000 Cherrington Pkwy
Moon Township, Pennsylvania 15108
USA

Attention: Kevin J. Lippert

The products listed below are eligible to bear the CSA Mark shown



Issued by: Steven Jeffery
Steven Jeffery

PRODUCTS

CLASS - C143201 - CIRCUIT BREAKERS-Moulded Case Type

For details related to rating, size, configuration, etc. reference should be made to the CSA Certification Record or the descriptive report.

PRODUCTS

CLASS 1432 01 - CIRCUIT BREAKERS - Moulded Case Type

Circuit breakers, moulded case type, R-frame, Series C, Type RD, RGH, RGHC, RDC, RGC and RGCC, 800-1600A, 1000-2000A and 1200-2500A and Type CRD and CRDC, 800-1600A and 1000-2000A, 2-, 3- and 4-pole, 600V ac, interchangeable solid state trip. Type RD-DC, 1600-3000A, 600V dc max, 3 poles in series. Type E2R, 800-1600A, 1000-2000A and 1200-2500A, 600V ac, 3-pole only.

Notes:

1. These circuit breakers may be marked with the following high current interrupting ratings in RMS symmetrical kilo amps:

	<u>Volts ac (50/60Hz)</u>		
<u>Type</u>	<u>240</u>	<u>480</u>	<u>600</u>



Certificate: 2434983
Project: 70149904

Master Contract: 163545
Date Issued: 2017-09-12

RD, CRD, RGH, RGHC, E2R	125	65	50
RDC, CRDC, RGC, RGCC	200	100	65

2. The mechanism is trip-free of the handle which assumes a mid-position between ON and OFF upon automatic tripping.
3. When factory sealed, these devices are suitable for use with reversed line/load connections.
4. Type RD circuit breakers may be provided with a "VISI-VUE" cover.
5. Types CRD and CRDC, RGHC, RGCC circuit breakers are suitable for use at 100 percent rating.
6. Type RD DC circuit breakers may be marked with the following high current interrupting ratings:

<u>Poles in Series</u>	<u>V dc</u>	<u>Interrupting Capacity (KA)</u>
1	125	50
2	250	50
3	600	65

APPLICABLE REQUIREMENTS

CAN/CSA-C22.2 No. 5-13 - Moulded Case Circuit Breakers



Supplement to Certificate of Compliance

Certificate: 2434983

Master Contract: 163545

*The products listed, including the latest revision described below,
are eligible to be marked in accordance with the referenced Certificate.*

Product Certification History

Project	Date	Description
70149904	2017-09-12	Update report 2434983 to cover addition of Type RGHC, RGCC and E2R circuit breakers
70032435	2015-06-02	Addition of RD-DC
2434983	2011-11-28	Report Updating per issued FIR. Addition of Types RGH and RGC